

DUNDEE CENTRAL SCHOOL WATER SAMPLE TESTING RESULTS 2023

Area tested	Date Tested	Lead result (5 ppb max)	Fails NYS Standard	Remediation
FIRST FLOOR				
Boiler room sink	10/3/2023	7	YES	sign posted
Boiler room Directors office bathroom sink	10/3/2023	12.5	YES	sign posted
Ice machine	10/3/2023	<1.0	NO	
Hose by washing machine in loading dock	10/3/2023	<1.0	NO	
Sink in kitchen staff bathroom	10/3/2023	3.5	NO	
Kitchen steam pot	10/3/2023	2.3	NO	
Kitchen island sink	10/3/2023	2.1	NO	
Sink in kitchen for washing hands	10/3/2023	4.7	NO	
Music suite sink	10/3/2023	1.6	NO	
Staff room 121 sink	10/3/2023	2.7	NO	
Staff room 121 bathroom sink	10/3/2023	3.7	NO	
HS CSEA room 112 bottle filler	10/3/2023	<1.0	NO	
HS CSEA room 112 drinking fountain	10/3/2023	<1.0	NO	
HS room 106 bottle filler	10/3/2023	1.4	NO	
HS room 106 drinking fountain	10/3/2023	1.6	NO	
HS room 105 sink	10/3/2023	18.4	YES	sign posted
HS room 105 hand washing sink	10/3/2023	6.2	YES	sign posted
HS room 101 sink	10/3/2023	2.1	NO	
SOS building bathroom sink	10/3/2023	1.3	NO	
HS concession stand sink	10/27/2023	1	NO	
HS gym hallway bottle filler	10/3/2023	3.4	NO	
HS gym hallway drinking fountain	10/3/2023	3.5	NO	
Wellness center entrance drinking fountain	10/3/2023	<1.0	NO	
Wellness center bottle filler (new 1/23)	10/3/2023	1.1	NO	
Wellness center drinking fountain	10/3/2023	<1.0	NO	
HS gym girls locker room drinking fountain	10/27/2023	4.2	NO	
HS gym girls entrance to gym drinking fountain	10/3/2023	2.9	NO	
HS gym girls entrance to gym bottle filler	10/3/2023	3.3	NO	
HS gym girls entrance to Wellness drinking fountain	10/3/2023	OFF	N/A	shut off
HS gym boys locker room drinking fountain	10/3/2023	2.8	NO	
HS gym boys entrance to gym drinking fountain	10/3/2023	2.3	NO	
HS gym boys entrance to gym bottle filler	10/3/2023	2.4	NO	
HS gym boys storage room drinking fountain	10/3/2023	13.2	YES	shut off
Trainers room sink (new 1/23)	10/3/2023	<1.0	NO	
Trainers room ice machine (new 1/23)	10/3/2023	<1.0	NO	
Pencil drinking fountain	10/3/2023	<1.0	NO	
Pencil bottle filler	10/3/2023	<1.0	NO	
Nurses office sink	10/3/2023	<1.0	NO	
Nurses office dentist sink	10/3/2023	1.9	NO	
Elementary classroom 372 sink	10/3/2023	1.3	NO	
Elementary classroom 373 sink	10/3/2023	<1.0	NO	
Elementary classroom 374 sink	10/3/2023	<1.0	NO	
Elementary girls pencil bathroom sink #4	10/3/2023	2.2	NO	

Elementary classroom 329 sink	10/3/2023	1.5	NO	
Public meeting room drinking fountain	10/3/2023	<1.0	NO	
Public meeting room bottle filler	10/3/2023	<1.0	NO	
Public meeting room kitchen sink	10/3/2023	<1.0	NO	
Elementary classroom 308 sink	10/27/2023	<1.0	NO	
Elementary classroom 308 drinking fountain	10/27/2023	<1.0	NO	
Elementary classroom 309 sink	10/3/2023	3	NO	
Elementary classroom 309 drinking fountain	10/27/2023	<1.0	NO	
Elementary classroom 310 sink	10/3/2023	1.8	NO	
Elementary classroom 310 drinking fountain	10/27/2023	<1.0	NO	
Elementary classroom 311 sink	10/3/2023	2.3	NO	
Elementary classroom 311 drinking fountain	10/3/2023	2.2	NO	
Elementary classroom 315 sink	10/3/2023	2.8	NO	
Elementary classroom 315 drinking fountain	10/27/2023	1.1	NO	
Elementary classroom 316 sink	10/3/2023	4.3	NO	
Elementary classroom 316 drinking fountain	10/27/2023	<1.0	NO	
Elementary 1st floor bathroom drinking fountain #1	10/3/2023	<1.0	NO	
Elementary 1st floor bathroom drinking fountain #2	10/3/2023	<1.0	NO	
Elementary classroom 320 sink	10/3/2023	3.3	NO	
Elementary classroom 320 drinking fountain	10/27/2023	<1.0	NO	
Elementary classroom 321 sink	10/3/2023	3.7	NO	
Elementary classroom 321 drinking fountain	10/27/2023	<1.0	NO	
Elementary computer lab classroom 322 sink	10/3/2023	4.2	NO	
Elementary classroom 367 sink	10/3/2023	2.3	NO	
Elementary classroom 367 bathroom sink	10/3/2023	3.1	NO	
Elementary classroom 368 sink	10/3/2023	2.5	NO	
Elementary classroom 368 bathroom sink	10/3/2023	4.3	NO	
Staff room soda machine sink	10/3/2023	2.8	NO	
Elementary classroom 370 sink	10/3/2023	2.5	NO	
Elementary classroom 370 bathroom sink	10/3/2023	3.1	NO	
Elementary classroom 371 sink	10/3/2023	1.5	NO	
Elementary classroom 371 bathroom sink	10/3/2023	3.6	NO	
Elementary office sink	10/3/2023	4	NO	
Discovery room sink #1	10/3/2023	2.4	NO	
Discovery room sink #2	10/3/2023	8.5	YES	sign posted
Discovery room sink #3	10/3/2023	20.4	YES	sign posted
Discovery room sink #4	10/3/2023	26.4	YES	sign posted
Elementary gym drinking fountain	10/3/2023	<1.0	NO	
Elementary gym bottle filler	10/3/2023	<1.0	NO	
Bus garage outside drinking fountain (right)	10/3/2023	1.3	NO	no test req
Bus garage outside drinking fountain (left)	10/3/2023	1.6	NO	no test req
Bus garage outside bottle filler	10/3/2023	1.7	NO	no test req
Field house drinking fountain east #1	10/3/2023	<1.0	NO	
Field house drinking fountain west #2	10/3/2023	<1.0	NO	
Field house outside hose faucet north #1	10/27/2023	<1.0	NO	
Field house outside hose faucet west #2	10/3/2023	1.7	NO	
Field house concession sink	10/27/2023	<1.0	NO	
Water spicket up by tennis courts	10/3/2023	4.8	NO	
Maintenance shop hose	10/3/2023	<1.0	NO	
SECOND FLOOR	10/3/2023		NO	

HS room 210 drinking fountain	10/3/2023	1.3	NO	
HS room 210 bottle filler	10/3/2023	1.7	NO	
HS library sink	10/3/2023	<1.0	NO	
HS staff room 228 kitchen sink	10/3/2023	1.6	NO	
HS room 219 drinking fountain	10/3/2023	<1.0	NO	
HS room 219 bottle filler	10/3/2023	1.1	NO	
HS counselors suite 223 bathroom sink	10/3/2023	6.2	YES	sign posted
HS girls bathroom by room 219 sink #1	10/3/2023	10.7	YES	sign posted
HS girls bathroom by room 219 sink #2	10/3/2023	3.6	NO	
HS girls bathroom by room 219 sink #3	10/3/2023	3.8	NO	
HS girls bathroom by room 219 sink #4	10/3/2023	39.9	YES	sign posted
Home economics room 222 kitchen 1 sink	11/16/2023	<1.0	NO	
Home economics room 222 kitchen 2 sink	10/27/2023	<1.0	NO	
Home economics room 222 kitchen 3 sink	10/27/2023	<1.0	NO	
Home economics room 222 kitchen 4 sink	10/3/2023	2.6	NO	
Elementary classroom 461 sink	10/3/2023	<1.0	NO	
Elementary classroom 462 sink	10/3/2023	2.4	NO	
Elementary classroom 463 sink	10/3/2023	<1.0	NO	
6th grade girls bathroom drinking fountain	10/3/2023	<1.0	NO	
6th grade girls bathroom bottle filler	10/3/2023	1.1	NO	
Elementary classroom 407 sink	10/3/2023	3.6	NO	
Elementary classroom 407 drinking fountain	10/3/2023	2.9	NO	
Elementary classroom 408 sink	10/3/2023	1.7	NO	
Elementary classroom 408 drinking fountain	10/27/2023	<1.0	NO	
Elementary classroom 409 sink	10/3/2023	2.8	NO	
Elementary classroom 409 drinking fountain	10/27/2023	<1.0	NO	
Elementary classroom 410 sink	10/27/2023	<1.0	NO	
Elementary classroom 414 sink	10/3/2023	4.5	NO	
Elementary classroom 414 drinking fountain	10/27/2023	<1.0	NO	
Elementary classroom 415 sink	10/3/2023	2.4	NO	
Elementary classroom 415 drinking fountain	10/3/2023	3.3	NO	
Elementary 2nd floor bathroom drinking fountain L	10/3/2023	1.2	NO	
Elementary 2nd floor bathroom drinking fountain R	10/3/2023	1.2	NO	
Elementary classroom 419 sink	10/3/2023	3.6	NO	
Elementary classroom 420 sink	10/3/2023	4.8	NO	
Elementary classroom 420 drinking fountain	10/27/2023	2.4	NO	
Elementary staff room kitchen sink	10/3/2023	2	NO	
Elementary staff room bathroom sink	10/3/2023	9.6	YES	sign posted
Elementary classroom 453 sink	10/27/2023	1.3	NO	
Elementary classroom 454 sink	11/16/2023	2.5	NO	
Elementary classroom 455 sink	10/27/2023	2.4	NO	
Elementary classroom 456 sink	10/27/2023	3.2	NO	
Elementary classroom 457 sink	10/27/2023	1.6	NO	
Elementary classroom 458 sink	10/3/2023	3	NO	
Elementary library sink	10/27/2023	<1.0	NO	